

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHC/KAD/18/2024-27

Dated: 23/07/26

It is certified that an inspection team headed by Dr. Geetha.MK. C.DMO UPHC KADUGODI

(Name of Officers with designation) from Dr. Geetha. M.K. PHED

inspected the MAPLE GLOBAL SCHOOL, Seegahalli, B-67

(Name & Address of the school) on 23/07/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. BAC/407/2026 dated 20/07/26

of Govt of Karnataka PHDT (PHED Lab) certified that

the MAPLE GLOBAL SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 22/07/2027

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

Dr. Geetha.MK.
C.DMO

ವೈದ್ಯಕೀಕಾರಿಗಳು

ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯಕೇಂದ್ರ

ಕಾಡುಗೋಡೆ

ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ

To MAPLE GLOBAL SCHOOL.

Sym. 6115, Seegahalli, Kadgod Post

(Name & Address of the Institution)

Bangalore - 560067

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Report of Bacteriological analysis of Water Sample

Date: 20/07/2086

Opinion							
Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
1860	RO Water	Nic	-	-	SPP	-	-
Note: M.P.N. Count: Most Potable number of Bacteria Per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coll found							

For Joint Director (Labs)

PUBLIC HEALTH INSTITUTE Microbiologist

Bengaluru

(Senior Specialist)
Public Health Institute
Bengaluru - 560 001

Advice: 1. Sample

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More